

Planning Division
15151 E. Alameda Parkway, Ste. 2300
Aurora, Colorado 80012
303.739.7250



April 2, 2019

James Rockhill
Berwick Electric Co.
3450 N. Nevada Avenue # 100
Colorado Springs, Co 80907

Re: Home Depot (Abilene Square)

Case Number: 1992-6015-17

Dear Mr. Rockhill:

Thank you for your initial submission for the above named minor amendment. We reviewed it and have the following comment:

Life Safety William Polk 303-739-7371 wpolk@auroragov.org

See blue comments on the Site Plan.

Sheet 3

1. How will this generator be powered? If supplied by diesel, please identify storage location and gallonage of belly tank.
2. Please identify the distance from the generator to the property line and to the edge of the building.

Real Property Darren Akrie 303-739-7331 dakrie@auroragov.org

1. Please note that there is a Drainage and Utility Easement located in the area of the new generator placement. A license agreement shall be required for the generator and pad to be placed within the easement. Please confirm with Aurora Water that they would be okay with a license agreement before you start the process. Contact Vern Adam 720-859-4324 vadan@auroragov.org in Aurora Water.

Please resubmit your work with the requested change. You may email it directly to me at wbarrett@auroragov.org . Should you have any questions you may contact me via email or by calling 303.739.7133

Sincerely,

W. David Barrett
Sr. Planner II