

November 13th 2019

City of Aurora: Planning & Development Services Department
Attention: Porter Ingram
15151 East Alameda Parkway, Ste. 2300
Aurora, CO 80012

Re: Gardens on Havana Anchors F, G and H

Minor Amendment: Case Number: 2011-6022-03

A. Life Safety

Comment: Please see blue fire life safety comments on site plan

Response: All items will comply

Sheet SP-C1

1. The Knox Boxes have been noted at all required entries.
2. The existing FDC has been noted and labeled on the plan

Sheet SP-E1

3. The building lighting has been clarified on the photometric plan. The accessible paths of travel will comply with the required 1 candela minimum. Once the storefront has been constructed and the "GG" fixtures have been relocated and the new "EE" under canopy lights have been installed, a photometric survey will be conducted. If any areas along the path of travel are below the required 1 candela then additional site walk lighting will be added.

Sheet SP-E2

4. New under canopy light "EE" has been added.

Additionally, please note that no changes have been made to the SP-C2, SP-C3, or L-3 plans; but they have been graphically updated to show the concise location of the new entries and trash enclosure.

Thank you for your assistance and don't hesitate to email or call with any questions or requests: Email: jessicaw@ctarch.com Phone: 847-298-1525.

Sincerely,

Jessica Wiebesiek

CAMBURAS & THEODORE, LTD.

847-298-1525

jessicaw@ctarch.com