

# MASTER UTILITY REPORT

FOR

**1450 S. ABILENE STREET**

**Located:**

**1450 South Abilene Street,  
Aurora, CO 80012**

Prepared: September 23rd, 2021

Revised: December 21<sup>st</sup>, 2021

Prepared for:

**MAA**

6815 Poplar Avenue, Suite 500  
Germantown, TN 38138

Prepared by:



**HARRIS KOCHER SMITH**

1120 Lincoln Street, Suite 1000  
Denver, CO 80203  
John Stafford, P.E.  
(303) 623-6300

HKS Project No. 210424

APPROVED FOR ONE YEAR FROM THIS DATE

\_\_\_\_\_  
CITY ENGINEER

\_\_\_\_\_  
DATE

\_\_\_\_\_  
WATER DEPARTMENT

\_\_\_\_\_  
DATE

## **TABLE OF CONTENTS**

TABLE OF CONTENTS .....	ii
I. INTRODUCTION.....	1
A. Site Location.....	1
B. Site Description .....	1
C. Existing Facilities .....	1
D. Proposed Project Description .....	2
II. PROPOSED SANITARY SEWER SYSTEM .....	2
A. Layout and Connection(s) to the Aurora Sanitary Sewer System.....	2
B. Average and Peak Flow Calculations .....	2
C. Conclusions.....	3
III. PROPOSED WATER SYSTEM .....	3
A. Layout and Connection(s) to the Aurora Potable Water System .....	3
B. Potable Water Demand (Peak and Average) .....	3
C. Fire Flow Demand .....	4
D. Available Pressure and Capacity.....	4
E. Network Model of System.....	5
V. CRITERIA AND DESCRIPTION .....	5
VI. CONCLUSIONS.....	5
References.....	6
APPENDIX A - Vicinity Map .....	A
APPENDIX B – City Utility Locate Maps .....	B
APPENDIX C – Overall Utility Plan .....	C
APPENDIX D – Sanitary Sewer Calculations.....	D
APPENDIX E – Water Calculations.....	E

## ***I. INTRODUCTION***

### **A. Site Location**

The proposed development of 1450 S. Abilene St. is located in the Northwest Quarter of Section 19, Township 4 South, Range 66 West of the 6th Principal Meridian, City and County of Aurora, State of Colorado. The Site is bounded by a multi-use commercial building to the North, single-family homes along East Arkansas Drive to the East, East Florida Avenue to the South, and South Abilene Street to West. A vicinity map is included with this report in Appendix A.

### **B. Site Description**

The Site encompasses approximately 4.41 acres of developed land. There is currently an existing building containing a fitness center along with internal roadways/fire lanes, parking areas, & landscaping.

The site generally flows South to North and West to East. Slopes range from approximately 0.5% to 10% throughout the site with a maximum of 23 feet of vertical elevation change across the site. Existing vegetation is predominately landscaped grass and a tree covered swale. The soil for this site is a combination of Hydrological Soil Group A and B.

### **C. Existing Facilities**

**Sanitary:** The City of Aurora owns and operates the sanitary sewer facilities within the vicinity of the Site. Sanitary facility locations within the proximity of the site are based on field survey and utility maps provided by the City of Aurora. A copy of the City's Utility Locate Map is included in Appendix B.

According to the City's Utility Locate Map and survey data, two existing 8" sanitary mains exist in East Florida Avenue with both heading South through commercial development towards East Jewell Avenue. One connection to the existing 8" sanitary main in East Florida Avenue that the site will connect to, flows East into an existing manhole near the intersection of East Florida Avenue and East Arkansas Drive. The main then routes South where it services existing commercial development including a condominium complex and shops. The second connection will occur in East Florida Avenue where it will flow East towards an existing manhole and also head south through an internal private roadway that services a hotel. These existing facilities are in place to serve the existing adjacent sites and residential development in accordance with previous studies and analyses. These existing utilities can be seen in the City's Utility Locate Map found in Appendix B. Internally to the Site; the existing sanitary sewer main is to be abandoned. Services for the existing building will be abandoned and removed at the time of the proposed building construction.

**Water:** Aurora Water owns and operates the existing water facilities surrounding the Site. Water facilities are located within the proximity of the site based on field survey data. An existing internal loop with multiple hydrant branches exists on site. The removal of a portion of this site along with relocating existing hydrants will take place during development. An exhibit showing existing water infrastructure is included in Appendix B.

## **D. Proposed Project Description**

The project proposes development of the Site into multi-family residential units with an attached parking garage structure and pool. Other Site improvements will include paved drives/walks, curb & gutter, utilities, water quality/stormwater detention and landscaping.

## ***II. PROPOSED SANITARY SEWER SYSTEM***

### **A. Layout and Connection(s) to the Aurora Sanitary Sewer System**

The sanitary service for the Site will be constructed through two 8-inch services that will connect to the sanitary sewer mains that exist within East Florida Avenue. The proposed 8-inch mains will split the building into two sanitary basins due to the existing topography of the Site and a building step. The Western portion of the building for the purpose of this report will be Basin 1 and the Eastern Portion of the building will be Basin 2. Proposed Sanitary mains will route the sewer to both the Southwest and Southeast of the Site. All proposed sanitary mains will be placed either in Aurora Public Right of Way or Easements dedicated to the city.

An additional service is being proposed to remove snowmelt and any excess water in the garage. These flows will be picked up by drains in the garage, routed through a sand-oil separator, and released into the public sanitary infrastructure. Peak flows have not been calculated for this service as it is to capture snowmelt only. There are no dwelling units or facilities in the garage.

Sanitary flows will be conveyed via the 8-inch services to collect wastewater effluent from the proposed building within the site. The Western portion of the building (Basin 1) will connect to the existing 8" main via a proposed manhole. The Eastern portion of the building (Basin 2) will connect to the existing sanitary main via a 50' +/- main extension. The proposed sanitary sewer mains and sanitary service connections are shown on the Overall Utility Plan included in Appendix C.

The 8" sanitary service lines will each be constructed at a minimum slope of 1.00%. The 8-inch mainlines will be constructed at a minimum slope of 0.40%, the maximum slope will be 10%, per Aurora Water's Water, Sanitary Sewer & Storm Drainage Infrastructure Standards & Specifications. A minimum of 10-feet horizontal clearance will be required from water lines and trees. A minimum of 5-feet horizontal clearance will be maintained from storm lines, with 10-feet clearance being maintained where possible. 8-inch mains have been calculated to have a capacity of 0.934 CFS at the minimum slope provided which is higher than the maximum proposed flows across the site.

### **B. Average and Peak Flow Calculations**

The Water, Sanitary Sewer & Storm Drainage Infrastructure Standards & Specifications – Section 5.03: Sanitary Sewer System Design Criteria was used to determine necessary calculations related to sanitary sewer flows (See Appendix D) Per the City Standards, the average sewage flow at mean velocity shall be two (2) feet per second or greater while never exceeding ten (10) feet per second The maximum allowable slope shall not exceed 10%.

The following equations were used to calculate the Average Day Demand and Peak Flow Demand for the Site:

**Aurora Water's: Water, Sanitary Sewer & Storm Drainage Infrastructure Standards & Specifications – Section 5**

**Criteria**

$AF = \text{UNITS} * \text{POPULATION} * 68 \text{ GPD}$

$PF = 5 \div p^{.167}$

$\text{INFILTRATION} = AF \times 0.1$

$\text{PEAK FLOW} = ((PF * AF) + \text{INFILTRATION})$

Using the information above and assuming 2.77 capita per unit, the projected peak flow from the Site to Building Basin 1 is 0.142 CFS and the peak flow from the Site to Building Basin 2 is 0.168 CFS. See Appendix D.

**C. Conclusions**

Existing peak flow in the existing offsite sanitary infrastructure is currently unknown. Aurora has documented the need to update their CIP to include future improvements to the sewer capacity in the future for this area. Furthermore, the addition of less than 0.15 CFS to existing infrastructure should be acceptable as currently configured. This addition makes up less than 15% of the capacity of the sanitary sewer in basin 1 and less than 16% of the capacity of the sanitary sewer that basin 2 is connected to. See calculations in Appendix D.

***III. PROPOSED WATER SYSTEM***

**A. Layout and Connection(s) to the Aurora Potable Water System**

The Site proposes to remove an internal loop from the existing 8" DIP water main on site. The 8" DIP Line on the Eastern side of the site running North-South will remain. The relocation of an existing hydrant will occur to allow for a revised drive aisle. The addition of a 3" Domestic Service will also be added to this loop while an existing hydrant on the Northern part of this run will remain. The existing connections for this water line are to the South in East Florida Avenue. An additional hydrant will be run off a section of the loop that will remain on the North side of the site. A layout of the proposed water main, service and overall utility plan is included in Appendix D.

**B. Potable Water Demand (Peak and Average)**

The design of the potable water distribution system was based on the design criteria given in section 5.02.3 of the Water, Sanitary Sewer & Storm Drainage Infrastructure Standards & Specifications published by Aurora Water. The potable water demand assumes 101 gallons/capita/day with an assumed average capita per unit of 2.77. The maximum day

peaking factor and max hour factor of 2.8 and 4.5 were utilized respectively. The total number of dwelling units for the proposed Site is 259. The total average daily demand and total maximum daily demand for the Site is 50.3 GPM and 140.9 GPM respectively. Domestic water demand calculations can be found in Appendix E. Table 1 represents the potable water demand for all buildings:

## **Aurora Water's Standards and Specifications Section 5.02.3 Design Criteria**

### **5.02.3 Domestic Water Demand per Zoning Classification**

<b>Residential</b>		
Zoning	People per Unit	Average Day Per Capita Flow (gpd)
Residential	2.77	101

<b>Non-Residential</b>			
Zoning	Average Day (gpd/acre)	Max Day (gpd/acre)	Max Hour (gpd/acre)
Commercial	1,500	4,200	6,750
Industrial (including schools)	1,200	3,360	5,400
Parks	1,800	5,040	N/A

Average Day Demand = (DU)\*(101GPD)\*(2.77persons)

Max Day Demand = (2.8)\*Average Day Demand

Max Hour Demand = (4.5)\*Max Day Demand

### **C. Fire Flow Demand**

A water model was created with multiple scenarios to account for differing demands and fire flows. The Max daily demand with fire flow used three hydrants to accommodate for 4000 GPM total, with all 3 operating at 1500 GPM. These flows were coupled with the Maximum Daily Demand for the building. Scenarios were laid out to sufficiently cover the whole Site in the event of a fire.

Per the 2018 IFC, the calculated fire flow for the apartment building is 6000 GPM. A 50% reduction is allowed for buildings that are sprinklered, the garage is not sprinklered so the total fire flow required for the building is 4000 GPM. Fire flow calculations can be found in Appendix E.

### **D. Available Pressure and Capacity**

The Aurora Water standards state that system must be analyzed to meet the maximum day plus fire flow demand with a residual pressure of no less than 20 psi at any point in the water distribution system.

The City of Aurora provided HGL Elevations and pressure zones for this site. Using this provided information, average day and maximum day demand pressures resulted in a

range of 102 psi and 107 psi, with fire scenario pressures between 100 psi and 106 psi. Water velocities in all pipes for all scenarios range between 0.11 feet per second (ft/s) and 9.57 feet per second (ft/s). The two hydrant laterals, when in use exceed the maximum 10 ft/s but only during a fire flow event. These 6 inch ductile iron fire hydrant laterals reach a maximum velocity of 17.02 ft/s. Velocities in the 8-inch water line exceed the maximum criteria in Aurora Water Specifications, however Aurora Water has reviewed and approved a variance for this condition. See Appendix E for calculations.

## **E. Network Model of System**

The system was modeled using three reservoirs set at the 5850 feet. The water model elevations for proposed water appurtenances are based on the proposed grading conditions for the Site. The WaterCAD model utilized a steady-state analysis to calculate pressures, velocities, and head losses of the model. A table of these values for each scenario can be seen in Appendix E.

## ***V. CRITERIA AND DESCRIPTION***

The principal design criteria used for this study was Section 5 of Aurora Water's: Water, Sanitary Sewer & Storm Drainage Infrastructure Standards & Specifications.

## ***VI. CONCLUSIONS***

The Site is proposed to be developed into a multi-family residential building with a variety of unit types (totaling 259 dwelling units).

As previously mentioned, the peak flows were determined for this site to be 0.142 CFS for the Western portion of the building and 0.168 CFS for the Eastern portion of the building. Aurora has stated that these peak flow calculations will be used to size their line in their revised CIP plans and report.


The water system is designed to provide a minimum of 20 psi residual pressure for fire flow, 4000 GPM for the hydrant laterals and up to 599.7 GPM during the maximum hour demand. The existing infrastructure being tied into has capacity per the estimated flows using Aurora Water's criteria.

## ***References***

1. Aurora Water. "Water. Sanitary Sewer & Storm Drainage Infrastructure Standards & Specifications." 2020.
2. International Code Council. "International Fire Code." 2018.




## ***APPENDIX A - Vicinity Map***



## VICINITY MAP


SCALE: 1"=2000'



SCALE: 1" = 2000'

## ***APPENDIX B – City Utility Locate Maps***

# Waste Water and Storm Water Assets



4/15/2021, 3:05:29 PM

## Ponds

- Ponds City
- Ponds Other Owner

## Storm Inlets

- Inlet Aurora
- Inlet Private or Other Owner

## Storm Outlets

- Aurora Storm Outlet
- Private or Other Owner Storm Outlet

## Storm Manholes

- Storm Manhole Aurora
- Storm Manhole Private or Other Owner

## Wastewater Manholes


- Manhole

## Storm Mains


- Aurora Storm Main
- Private or Other Owner Storm Main

## Wastewater Mains

- Wastewater Main
- Other
- Fire Hydrants
- Storm Fittings
- Tee Fitting









## ***APPENDIX C – Overall Utility Plan***

MAA ABILENE MULTIFAMILY | SITE PLAN  
1450 S ABILENE ST  
AURORA, COLORADO


APPLICANT:  
MAA Communities

5040 Addison Cir #200  
Addison, TX 75001  
Bart French

NOT FOR  
CONSTRUCTION

DATE:  
09/29/21 SITE PLAN 01  
11/19/21 SITE PLAN 02  
01/07/22 SITE PLAN 03

SHEET TITLE:  
OVERALL UTILITY PLAN



**LEGEND:**

PROPERTY BOUNDARY  
RIGHT OF WAY  
LOT LINE  
STORM SEWER W/ MANHOLE AND INLET  
SANITARY SEWER WITH MANHOLE

**EXISTING**

ST  
SS

**PROPOSED**

ST  
SS

WATER LINE

W

WATER METER PIT

W

FIRE HYDRANT

W

STREET LIGHT

W

SIGN

W

UNDERGROUND TELECOMMUNICATION

UT

UNDERGROUND ELECTRIC

UE

UNDERGROUND TELECOMMUNICATION DEMO

UT

UNDERGROUND UNDERGROUND ELECTRIC DEMO

UE

WATER LINE DEMO

W

STORM SEWER W/ MANHOLE DEMO

ST

**NOTES:**

1. THE PROPOSED STORM SEWER SYSTEM SHOWN IS PRIVATE AND WILL BE MAINTAINED BY BUILDING MAINTENANCE SERVICES

LOT 6

LOT 5

OWNER: LUCERO PETER A,  
LUCERO VALERIE ANN

LOT 4

OWNER: HA THUYEN TO,  
HA NGA TO, HA HAO QUOC

**BLOCK 1  
SABLERIDGE SUBDIVISION  
FILING NO. 2  
B.39 P.66**

LOT 3


OWNER: LANE ALESHIA  
& RICHARD JOEL

LOT 2

OWNER: WETHERBEE KRISTAL,  
BINGHAM LINDA

LOT 1

OWNER: HOGE LAND KEITH



30 0 30 60  
SCALE: 1" = 30'

## ***APPENDIX D – Sanitary Sewer Calculations***



### Approximate Proposed Sanitary Peak Flows Table

[illegible]

## ***APPENDIX E – Water Calculations***

**FIRE FLOW CALCULATIONS**

Project Name 1450 S. Abilene St  
Last Edited 1/6/2022  
Edited By HGT

Site Area (ac) = 4.41  
Zoning = MU-C

Code Used For Analysis: 2018 IFC

Building A		Sprinkled?					
		Yes	No				
Description	Type	Area (sf)	Area (sf)	Area Percentage	Full GPM req	Sprinkled req	Apply Perc
Garage	IA	-	122,000	31.16%	6,000.00	6,000.00	1,869.58
	IB						
	IIA						
Residential	IIIA	269,531	-	68.84%	6,000.00	3,000.00	2,065.00
	IV						
	V-A						
	IIB						
	IIIB						
	V-B						
Total		391,531		3,934.58			

TOTAL UNADJUSTED FIRE FLOW (gpm)=	6,000
50% REDUCTION W/ SPRINKLE (gpm)=	3,935
TOTAL HYDRANTS REQUIRED PER IFC APPENDIX C=	4



Abilene Apartments  
 Project #210424  
 Date: 09/13/2021

BUILDING NUMBER	# OF UNITS	AVG. DEMAND (GPCD)	AVG DAILY DEMAND (GPD)	AVG DAILY DEMAND (GPM)	MAX DAILY DEMAND (PF=2.8) (GPM)	MAX HOUR DEMAND (PF=4.5) (GPM)	SPRINKLER FIRE FLOWS (GPM)	FIRE JUNCTION NUMBER
BUILDING A-1	259	101	68536.58	47.6	133.3	599.7	1750.0	Bldg-A1
TOTAL	259	101	68536.58	47.59	133.3	599.7		

Total DU = 259  
 Area = 4.41  
 DU/Acre = 59

**Residential:**


Avg day demand = (DU \* 101GPD/person \* 2.77 persons) (GPD)  
 Avg day demand = Avg day/1440min/day (GPM)  
 Max Day = Avg Day \* 2.8 (GPM)  
 Max Hr = Max Day \* 4.5 (GPM)  
 Avg day demand = (101GPCD\*# OF UNITS\*PERSON PER UNIT) (GPD)



SCALE: 1" = 60'

# ABILENE - WATERCAD LAYOUT

SCALE: 1"=60'



**Scenario: Average Daily Demand**  
**Current Time Step: 0.000 h**  
**FlexTable: Pipe Table**

Label	Length (Scaled) (ft)	Diameter (in)	Material	Hazen- Williams C	Flow (gpm)	Velocity (ft/s)	Headloss Gradient (ft/ft)
A-1	44	8.0	Ductile Iron	130.0	21	0.13	0.000
A-2	45	8.0	Ductile Iron	130.0	21	0.13	0.000
A-3	255	8.0	Ductile Iron	130.0	21	0.13	0.000
A-4	38	8.0	Ductile Iron	130.0	-30	0.19	0.000
A-5	25	8.0	Ductile Iron	130.0	-30	0.19	0.000
A-6	116	8.0	Ductile Iron	130.0	-30	0.19	0.000
A-7	304	6.0	Ductile Iron	130.0	0	0.00	0.000
A-8	120	8.0	Ductile Iron	130.0	0	0.00	0.000
A-9	10	6.0	Ductile Iron	130.0	0	0.00	0.000
A-10	23	6.0	Ductile Iron	130.0	0	0.00	0.000
L-1	25	6.0	Ductile Iron	130.0	0	0.00	0.000
L-3	20	6.0	Ductile Iron	130.0	0	0.00	0.000

K:\210424\Documents\Utilities\Water\Abilene.wtg

**Scenario: Average Daily Demand**  
**Current Time Step: 0.000 h**  
**FlexTable: Junction Table**

---

Label	Elevation (ft)	Demand (gpm)	Pressure (psi)
G-1	5,603.54	0	107
N-1	5,614.19	0	102
N-2	5,615.14	0	102
N-3	5,605.93	50	106
N-4	5,603.54	0	107
N-5	5,601.60	0	107

K:\210424\Documents\Utilities\Water\Abilene.wtg

**Scenario: Maximum Daily Demand**  
**Current Time Step: 0.000 h**  
**FlexTable: Pipe Table**

Label	Length (Scaled) (ft)	Diameter (in)	Material	Hazen- Williams C	Flow (gpm)	Velocity (ft/s)	Headloss Gradient (ft/ft)
A-1	44	8.0	Ductile Iron	130.0	58	0.37	0.000
A-2	45	8.0	Ductile Iron	130.0	58	0.37	0.000
A-3	255	8.0	Ductile Iron	130.0	58	0.37	0.000
A-4	38	8.0	Ductile Iron	130.0	-83	0.53	0.000
A-5	25	8.0	Ductile Iron	130.0	-83	0.53	0.000
A-6	116	8.0	Ductile Iron	130.0	-83	0.53	0.000
A-7	304	6.0	Ductile Iron	130.0	0	0.00	0.000
A-8	120	8.0	Ductile Iron	130.0	0	0.00	0.000
A-9	10	6.0	Ductile Iron	130.0	0	0.00	0.000
A-10	23	6.0	Ductile Iron	130.0	0	0.00	0.000
L-1	25	6.0	Ductile Iron	130.0	0	0.00	0.000
L-3	20	6.0	Ductile Iron	130.0	0	0.00	0.000

K:\210424\Documents\Utilities\Water\Abilene.wtg



**Scenario: Maximum Daily Demand**  
**Current Time Step: 0.000 h**  
**FlexTable: Junction Table**

---

Label	Elevation (ft)	Demand (gpm)	Pressure (psi)
G-1	5,603.54	0	107
N-1	5,614.19	0	102
N-2	5,615.14	0	102
N-3	5,605.93	141	106
N-4	5,603.54	0	107
N-5	5,601.60	0	107

K:\210424\Documents\Utilities\Water\Abilene.wtg

**Scenario: Maximum Hour Demand**  
**Current Time Step: 0.000 h**  
**FlexTable: Pipe Table**

Label	Length (Scaled) (ft)	Diameter (in)	Material	Hazen- Williams C	Flow (gpm)	Velocity (ft/s)	Headloss Gradient (ft/ft)
A-1	44	8.0	Ductile Iron	130.0	261	1.67	0.002
A-2	45	8.0	Ductile Iron	130.0	261	1.67	0.002
A-3	255	8.0	Ductile Iron	130.0	261	1.67	0.002
A-4	38	8.0	Ductile Iron	130.0	-373	2.38	0.003
A-5	25	8.0	Ductile Iron	130.0	-373	2.38	0.003
A-6	116	8.0	Ductile Iron	130.0	-373	2.38	0.003
A-7	304	6.0	Ductile Iron	130.0	1	0.01	0.000
A-8	120	8.0	Ductile Iron	130.0	0	0.00	0.000
A-9	10	6.0	Ductile Iron	130.0	0	0.00	0.000
A-10	23	6.0	Ductile Iron	130.0	0	0.00	0.000
L-1	25	6.0	Ductile Iron	130.0	0	0.00	0.000
L-3	20	6.0	Ductile Iron	130.0	0	0.00	0.000

K:\210424\Documents\Utilities\Water\Abilene.wtg

**Scenario: Maximum Hour Demand**  
**Current Time Step: 0.000 h**  
**FlexTable: Junction Table**

---

Label	Elevation (ft)	Demand (gpm)	Pressure (psi)
G-1	5,603.54	0	106
N-1	5,614.19	0	102
N-2	5,615.14	0	102
N-3	5,605.93	634	105
N-4	5,603.54	0	106
N-5	5,601.60	0	107

K:\210424\Documents\Utilities\Water\Abilene.wtg

**Scenario: Maximum Hourly Demand w/ Fire Flow**  
**Current Time Step: 0.000 h**  
**FlexTable: Pipe Table**

Label	Length (Scaled) (ft)	Diameter (in)	Material	Hazen- Williams C	Flow (gpm)	Velocity (ft/s)	Headloss Gradient (ft/ft)
A-1	44	8.0	Ductile Iron	130.0	1,392	8.88	0.034
A-2	45	8.0	Ductile Iron	130.0	1,392	8.88	0.034
A-3	255	8.0	Ductile Iron	130.0	-108	0.69	0.000
A-4	38	8.0	Ductile Iron	130.0	-742	4.74	0.011
A-5	25	8.0	Ductile Iron	130.0	-742	4.74	0.011
A-6	116	8.0	Ductile Iron	130.0	-1,042	6.65	0.020
A-7	304	6.0	Ductile Iron	130.0	4	0.04	0.000
A-8	120	8.0	Ductile Iron	130.0	1,500	9.57	0.039
A-9	10	6.0	Ductile Iron	130.0	1,500	17.02	0.157
A-10	23	6.0	Ductile Iron	130.0	1,500	17.02	0.157
L-1	25	6.0	Ductile Iron	130.0	-1,500	17.02	0.157
L-3	20	6.0	Ductile Iron	130.0	0	0.00	0.000

K:\210424\Documents\Utilities\Water\Abilene.wtg

**Scenario: Maximum Hourly Demand w/ Fire Flow**  
**Current Time Step: 0.000 h**  
**FlexTable: Junction Table**

---

Label	Elevation (ft)	Demand (gpm)	Pressure (psi)
G-1	5,603.54	300	106
N-1	5,614.19	0	101
N-2	5,615.14	0	100
N-3	5,605.93	634	104
N-4	5,603.54	0	106
N-5	5,601.60	0	105

K:\210424\Documents\Utilities\Water\Abilene.wtg

**Scenario: Maximum Hourly Demand w/ Fire Flow**  
**Current Time Step: 0.000 h**  
**FlexTable: Hydrant Table**

---

Label	Elevation (ft)	Demand (gpm)	Pressure (psi)
H-2	5,602.25	1,500	104
H-1	5,615.04	1,500	99
H-9	5,603.17	0	106
H-4	5,615.00	1,500	100

K:\210424\Documents\Utilities\Water\Abilene.wtg