



**PHA-HAZOP ANALYSIS
FIELDWIDE -NIOBRARA**

1. Well Head, HP / LP Separator (Heater Treater) Green - Os Sales Gas Orange - Xs				Risk Ranking						HAZOP Recommendations						
Deviation	Causes	Consequences	Description	IPL?	S	E	Max Sev	L	RR	LOPA?	HAZOP Recommendations	Responsibility	Date Complete	Action Taken		
1. More Flow	2. Failure of control valve / control loop Choke 100x Open when it is desired to be closed.	2. Increased flow/pressure to LP separator. DP = 260 psig Well Pressure ~ 1000 psig Overpressure > 3	5. PSV-2001 @ 260 psig vents to the atmosphere	Yes	5		5	2	II	Yes	1.1.2. No LOPA Gap, Sufficient safeguards provided	Mead	1/29/2018	No LOPA gap, no additional actions.		
			6. PAHH-2001 will close ESDV on well	Yes												
			7. PAHH-103x will close ESDV at well	No												
3. Inadvertent Opening or failure to car-seal 2" manual valve between line 1013 and 2011 open.	2. Potential for flow from well to divert to the VRT tower. DP- V-3001 @ 125 psig Well Pressure~ 1000 psig Overpressure > 3 times	10. 2" valve on 1013 is CSC	11. Normally closed valve at header.								1.1.3. No LOPA Gap, Sufficient safeguards provided	Mead	1/29/2018	No LOPA gap, no additional actions.		
			12. PSV-3001 @ 125 psig vents to atmosphere	Yes												
			5. PSV-2001 @ 260 psig vents to the atmosphere	Yes	5		5	2	II	Yes					1.1.3.2. No LOPA Gap, Sufficient safeguards provided	
			6. PAHH-2001 will close ESDV on well	Yes												
4. Failure of control valve / control loop LCV-2001 Open when desired to be closed. or manual valves closed	1. Loss of liquid level with gas blow thru to V-2101. DP V-2101 = 125 psig Well pressure ~ 1000 psig Overpressure > 3	8. PSV-2101 @ 125 psig vents to atmosphere	9. PAHH-2101 will close ESDV on well								1.1.4. No LOPA Gap, Sufficient safeguards provided	Mead	1/29/2018	No LOPA gap, no additional actions.		
			41. PAHH-103x will close ESDV at well	Yes												
			10. Contaminants	3. Sand from the Frac	1. Increased corrosion of piping with plugging of equipment. No safety hazard, an Operational issue.											
19. Maintenance	1. Corrosion of Pipeline over time.	1. Potential for leak of pipeline overtime.								1.19.1. Ensure that there is a PM for the cathodic protection on the pipeline	Mead	3/30/2018	Bronco PM exists for cathodic protection testing			
2. Flash Gas / VRU Purple - - - (dashed line)																
1. More Flow	3. Failure of TCV-3100/3102 - B to A Open More than desired.	1. Majority of Lube Oil around cooler. Potential for bearing failure due to lube oil temperature greater than desired.	17. TAHH-3210/20 will shutdown VRU SC-3101/2.		3		3	2	II	No						
			18. TALL-3210/20 will shutdown SC-3101/2.		3		3	2	II	No						
2. Less Flow	2. Plugging of demister pad in V-3101/V-3102.	1. Increased pressure to VRU. V-3102 @ 100 psig V-2101 @ 125 psig Overpressure @ 1.25 Gasket leaks not thought to occur Although PSV is located above the demister, complete blocking of the relief path thru the vessel is not anticipated as paraffin not thought to be an issue	16. PSV-3102 @ 100 psig sits above the demister pad		3	2	3	2	II	No						
			3. Reverse / Mis-Directed Flow	1. Failure of 2" check valve to prevent backflow - downstream of PCV-2001B	1. PCV-2001B fails there is a potential to for flow from other wells/separators to back flow into V-2101 which could exceed the design of PSV-2101							2.3.1. Ensure check valve downstream of PCV-2001B is listed as a critical check - needs to be dissimilar, numbered, and put into a PM program.	Mead	8/30/2018	1st check valve is a swing check, 2nd check valve is a piston check. Not numbered or in a PM program.	
3. Low Pressure	3. Failure of PCV-3130/3230 closed more than desired. or manual valve closed	1. Blocked discharge on SC-3102 outlet. Potential Overpressure A Class Piping: 285 psig SC-3102: ???? Overpressure assuming > 3 times or manual valves closed	13. Class I / Div I within enclosure		3		3	3	II	No						
			14. No hydrocarbon detection within the enclosure													
			15. Cooler location is near vent location and has fan for dispersion.													
5. Low Pressure	3. Failure of PCV-3130/3230 closed more than desired. or manual valve closed	1. Blocked discharge on SC-3102 outlet. Potential Overpressure A Class Piping: 285 psig SC-3102: ???? Overpressure assuming > 3 times or manual valves closed	19. PSV-3220 @ 200 psig vents to the atmosphere	Yes	4		4	2	II	Yes	2.5.3. No LOPA Gap, Sufficient safeguards provided					
			20. PAHH-3230 will shutdown SC-3102	No									Mead	1/29/2018	No LOPA gap, no additional actions.	
6. High Temperature	1. Poor performance of After cooler EA-3122 / Oil Cooler. Fans not running.	2. For oil. Potential for bearing failure due to lube oil temperature greater than desired.	17. TAHH-3210/20 will shutdown VRU SC-3101/2.		3		3	2	II	No						
7. Low Temperature	1. Better than design performance of After cooler EA-3122 / Oil Cooler. Cold Ambient Conditions	2. For oil. Potential for damage to the compressor due to lube oil colder than desired.	18. TALL-3210/20 will shutdown SC-3101/2.		3		3	2	II	No						
10. Contaminants	1. Condensate / Water contamination of oil	1. Potential loss of seal and bearing failure overtime.	22. 3000 Run Hour PM - inspection of lube oil - filter, oil,		3		3	2	II	No						
16. Mis-identification	1. PSV Weep Holes	1. Spec / PSSR Discrepancy									2.16.1. Weep Hole Requirement - inconsistency between P&ID which shows 1/4" weep hole, PSSR asks for 3/8" weep hole - decide which is correct.	Mead	3/30/2018	Utilize both depending on size of PSV outlet pipe.		
3. Flash Gas / Vent Orange - AAAAA																

2. Less Flow	2. Plugging of Flame Arrestor FA-9410B. or manual valves closed	1. Loss of vapor line from the storage tanks to flare. Potential overpressure of atmospheric oil tanks due to ambient temperature changes. Potential overpressure with Fire.	24. PVRV-4001/2/3/4/5/6/7 and 4101/02 @ 16 oz vent to the atmosphere			3	2	3	2	II	No				
4. High Pressure	1. Failure of PCV-3100 Open more than desired. or manual valves being open	1. Upstream pressure < 5 psig. Loss of VRU gas to the combustor. Reduced environmental gas recovery. No hazardous consequence, an Environmental Issue.				1	2	1	2	I	No				
5. Low Pressure	2. Failure of PCV-4101 Closed more than desired. or manual valve closed	1. Upstream pressure > 3 oz. Loss of vapor line from the storage tanks to flare. Potential overpressure of atmospheric oil tanks due to ambient temperature changes. Potential overpressure with Fire.	24. PVRV-4001/2/3/4/5/6/7 and 4101/02 @ 16 oz vent to the atmosphere			3	2	3	2	II	No				
6. High Temperature	1. Combustion of Niobara Gas - High Heating Value	1. Temperature within the combustor has exceeded the design of the refractory / refractory support pins. Potential for a gas leak with fire from the combustor.	25. Visual inspection of the combustor is part of normal operator rounds. Combustor is painted - paint blistering or hot spot can be noticed.			3		3	3	II	No				
19. Maintenance	1. Isolation of V-9301/02 for maintenance.	1										3.19.1. Consider revision to allow for installation of isolation valves around V-9301/02 to allow for easier isolation for preventative maintenance. As valve installation does not create any new hazard (different than the flame arrestors being plugged) they do not require that valves be car sealed open.	Mead	3/30/2018	Isolation valves are located at flash gas header and upstream of flame arrestor. No extra work to utilize these valves for isolation.
4. Oil to VRT Pink Diamonds															
1. More Flow	1. Failure of control valve / control loop LCV-2101A Open when it is desired to be closed.	2. Potential for fire tube failure due to loss of sufficient liquid level in V-2101/2/3/4. Heater Treater Fire	55. LSL-2104 will shutdown BMS system.			3		3	2	II	No	4.1.1. Ensure Low Level Shutdown Taps are appropriately set to prevent fire tube exposure for all heater treaters V-2101/2/3/4 and V-2901. Also confirm whether the heat transfer differences for hydrocarbon or water coverage of the fire tubes creates issues to prevent damage.	Mead	3/30/2018	Taps are located correctly to prevent burning through fire tubes. Tubes are adequate for heat transfer coefficient differences between water and HC.
	2. Failure of control valve / control loop LCV-2901A Open when desired to be closed.	2. Potential for fire tube failure due to loss of sufficient liquid level in V-2901. Heater Treater Fire	37. LSL-2901 will shutdown BMS system.			3		3	2	II	No				
	3. Inadvertent opening of 2" manual valve on line 2041 - produced fluids bypass line. same for line 2031 / 2021 / 2011	1. Increased vapor to the atmospheric storage tanks. Tank Overpressure and Fire	54. PVRV-4001/2/3/4/5/6/7 @ 16 oz vent to the atmosphere			3		3	2	II	No				
			26. Open vent line to the flare - 4"												
	4. Inadvertent opening of 2" manual valve bypass around V-3001.	1. Potential to have unvaporized crude to atmospheric storage tanks. No safety hazard, a potential Environmental violation.				1	2	2	3	II	No				
	5. Inadvertent opening of 2" manual valve (recycle oil) to P-4201.	1. Potential to drain water and /or unvaporized crude to atmospheric oil tanks. No safety hazard, a potential Environmental violation.				1	2	2	3	II	No				
2. Less Flow	8. Inadvertent closure of 4" manual valves to truck load out station.	2. Inability to load out water. Potential liquid filling of water tanks TK-4101/02 with potential water spill to dike through thief hatches. Environmental issue, no safety hazard.	50. Tank Dike			1	1	1	3	I	No	4.2.8. Confirm whether it is desired for LSHH-4101/02 to ESD the facility as there is minimum safety risk with overflowing water tanks.	Mead	3/30/2018	Leave ESD on HH as designed. There is potential for HC to be recycled into the water tanks as well as heightened awareness of environmental issues in the state of Colorado.
			51. LSHH-4101/02 will ESD the facility												
			52. Equalization line between water / oil storage tanks.												
	10. Inadvertent closing of butterfly valves (SP-02) on equalization lines between oil tanks.	1. Loss equalization between the tanks. Potential to carry over liquid out of the thief hatch (accidental lifting) to the tank dike. Potential Tank Dike with Fire	27. LSHH-4001/2/3/4/5/6/7 and 4101/02 will ESD the well			3		3	2	II	No	4.2.10. Review use of butterfly valves on equalization between tanks. As depicted the equalization line is normally open. During review it was mentioned that the tanks must be fully isolated prior to sales - not sure whether the isolation includes the equalization line. Need to confirm requirements for sales and also if the valve must be used, it must be accessible.	Mead	3/30/2018	Equalization line isolation valves are Normally Closed and are only used as an exception. P&ID's will be changed to depict this.
			28. LAHH-4001/2/3/4/5/6/7 and 4101/02 will ESD the well												
	11. Inadvertent closing of 2" manual valve to P-4201. or manual valve closed	1. Potential to damage P-4201 due to a blocked suction. Pump damage with seal leak	29. Operating Procedures			3		3	3	II	No				
3. Reverse / Mis-Directed Flow	5. Poor Hose Connection at Oil Load Out. Manual drain left open Hole in load out hose	1. Leak to the load out container. Environmental Issue				1	1	1	3	I	No				
5. Produced Water Blue Squares															
1. More Flow	1. Failure of control valve / control loop LCV-2101B. Open when desired to be closed.	1. Water level in V-2101 will be drained with gas blow thru to the produced water tanks. Increased vapor to the atmospheric storage tanks. Tank Overpressure and Fire	49. PVRV-4101/02 @ 16 oz vent to the atmosphere			3		3	2	II	No				

	5. Failure of control valve / control loop FCV-2901A Open when desired to be closed.	1. Increased fuel gas flow to the main burner. Resulting increased firing. Process hotter than desired. Potential to exceed design temperature for atmospheric storage - potential flashing of water resulting in damage.	35. TAHH-2901A will shutdown BMS closing SDV-2901/2901B.		3	2	3	2	II	No				
		2. Increased fuel gas flow to the main burner. Resulting increased firing resulting in a high stack temperature. Potential to exceed the design temperature of the stack.	36. No safeguards listed		3	2	3	3	II	No				
	7. Failure of control valve / control loop SDV-9201 Open when desired to be closed. [Safety System Valve]	1. The SDV-9201 valve is desired to be closed when there is a ??????												
	8. Failure of control valve / control loop SDV-9420 Open when desired to be closed. [Safety System Valve]	1. The SDV-9420 valve is desired to be closed when there is a ??????												
2. Less Flow		2. Downstream pressure > 15 psig. Higher pilot gas than desired potential to lift flame off of the pilot resulting in uncombusted gas from the flare stack. Environmental incident	39. BMS Flame detection will ESD well.		1	1	1	3	I	No				
	9. Plugging of Flame Arrestor FA-9201.	1. Blocked flow to the hp flare. Upstream pressure > 100 psig. Potential to have an environmental release of uncombusted material from the flare KO drum. A class piping @ 285 psig V-2001/2/3/4 @ 260 psig (limited by PSV-2001) Overpressure = not anticipated	45. PSV-9001 @ 125 psig vents to the atmosphere		1	1	1	2	I	No				
			46. PAHH-2001 will close ESDV on well											
3. Reverse / Mis-Directed Flow	3. Tube Leak in V-2901.	1. Potential for fire tube failure with oil to fuel gas resulting in ignition and fire of the treater.	36. No safeguards listed		3	2	3	3	II	No				
4. High Pressure	1. Failure of PCV-2201 Open more than desired	1. Downstream pressure > 30 psig. V-2201 will be overpressured. V-2001 @ 250 psig V-2201 @ 125 psig Overpressure = 2 times Gasket / Pin Hole failure	33. PSV-2201 @ 125 psig vents to the atmosphere	Yes	4	2	4	2	II	Yes	6.4.1. No LOPA Gap, Sufficient safeguards provided	Mead	1/29/2018	No LOPA gap, no additional actions.
	2. Failure of regulator PCV-2101A Open when desired to be closed.	1. Downstream pressure > 12 psig Increased fuel gas flow to the main burner. Resulting increased firing. Process hotter than desired. Potential to exceed design temperature for atmospheric storage - potential flashing of water resulting in damage.	42. TAHH-2101A will shutdown BMS closing SDV-2101		3		3	2	II	No	6.4.2. Update P&ID 2101/2/3/4 to show high temperature shutdown - the transmitter is showing whereas the high shutdown TAHH isn't represented on the P&ID.	Mead		TAHH not shown on P&IDs
	3. Failure of PCV-2101 Open more than desired.	1. Downstream pressure > ?? psig Increased fuel gas pressure to the pilot. Potential to blow pilot out and have unrestricted fuel gas venting to the atmosphere.	44. BMS Flame detection will close FCV-2101B & SDV-2101.		3	1	3	2	II	No	6.4.3. Update P&ID 2101/2/3/4 to show set pressure for regulator PCV-2101/2/3/4	Mead		Both 2101A/2A/3A/4A and 2101B/2B/3B/4B were updated to show set pressure
	5. Failure of PCV-2901B Open more than desired.	1. Downstream pressure > 5 psig. Increased fuel gas pressure to the pilot. Potential to blow pilot out and have unrestricted fuel gas venting to the atmosphere.	34. BMS Flame detection will close FCV-2901B & SDV-2901.		3	1	3	2	II	No				
5. Low Pressure	5. Failure of PCV-2901B Closed more than desired. or manual valves closed	1. Downstream pressure > ?? psig. Loss of pilot gas. Inability to start heater treater resulting in an inability to break emulsion of recycled oil. No safety hazard, an Operational issue.									6.5.5. Update P&ID 2901 to show set pressure for regulator PCV-2901B	Mead	6/30/2018	Complete PCV-2901B is set @ 5 psig
5. Low Pressure	9. Failure of PCV-7100 Closed more than desired.	1. Upstream pressure > 100 psig. Potential for increased pressure to the sales gas line. A class piping @ 285 psig V-2001/2/3/4 @ 260 psig (limited) Overpressure not anticipated for piping - may have higher pressure than sales contract.	47. PSV-2001 @ 260 psig vents to the atmosphere		1	1	1	2	I	No				
			48. PAHH-2001 will close ESDV on well											
16. Mis-Identification	1. Page Connection - incorrect	1. P&ID Redline Error									6.16.1. Update P&ID connector on left hand side of the page - currently says from P&ID 2001 and it should be from P&ID 2002.	Mead	6/30/2018	Complete now says P&ID 2002

	NIO-56020-00-011-2901	5. Failure of control valve / control loop FCV-2901A Open when desired to be closed.	1. Increased fuel gas flow to the main burner. Resulting increased firing. Process hotter than desired. Potential to exceed design temperature for atmospheric storage - potential flashing of water resulting in damage.	35. TAHH-2901A will shutdown BMS closing SDV-2901/2901B.				3	2	3	2	II	No					
			2. Increased fuel gas flow to the main burner. Resulting increased firing resulting in a high stack temperature. Potential to exceed the design temperature of the stack.	36. No safeguards listed				3	2	3	2	II	No					
	NIO-56020-00-011-2901	6. Failure of control valve / control loop SDV-2901 Open when desired to be closed. [Safety System Valve]	1. Failure of this safety system valve did not initiate the event. This valve is desired to be open during normal operation. If it fails to close during an ESD / BMS event unregulated fuel gas may continue to the main burner. Manual block valves are available to be closed.															
	NIO-56020-00-011-9201	7. Failure of control valve / control loop SDV-9201 Open when desired to be closed. [Safety System Valve]	1. The SDV-9201 valve is desired to be closed when there is a ??????															
	NIO-56020-00-011-9401	8. Failure of control valve / control loop SDV-9420 Open when desired to be closed. [Safety System Valve]	1. The SDV-9420 valve is desired to be closed when there is a ??????															
2. Less Flow	NIO-56020-00-011-2101	1. Failure of control valve / control loop FCV-2101A Closed when desired to be open. or SDV-2101 closed or manual valves closed	1. Loss of fuel gas to the main burner. Potential to have insufficient heat to remove emulsion from oil. No safety hazard, an operational issue.															
	NIO-56020-00-011-2102																	
	NIO-56020-00-011-2103																	
	NIO-56020-00-011-2104																	
	NIO-56020-00-011-2101	2. Failure of control valve / control loop FCV-2101B Closed when desired to be open	1. Loss of pilot gas. Inability to start heater treater resulting in a delayed start-up or shutdown of heater treater. No safety hazard, an operational issue.															
	NIO-56020-00-011-2102																	
	NIO-56020-00-011-2103																	
	NIO-56020-00-011-2104																	
	NIO-56020-00-011-2101	3. Plugging of Screen on Heater Treater Stack (insect / debris)	1. Full plugging of the incinerator stack is not considered a creditable consequence. A partial plugging is considered an Operational issue as the control of the heat may be impacted.															
	NIO-56020-00-011-2102																	
	NIO-56020-00-011-2103																	
	NIO-56020-00-011-2104																	
	NIO-56020-00-011-9800	4. Inadvertent closure of manual valve to V-2902 from main header.	1. Loss of fuel gas to V-2902. Loss of fuel gas to provide pressure to V-2901 and to the V-2901 burners. No safety hazard, an operational issue. Results for both scenarios are covered separately.															
	NIO-56020-00-011-2901	5. Inadvertent closure of 1" manual valve between V-2902 and V-2901 ovhd line 2303.	1. Loss of fuel gas flow to the V-2901. Inability to provide pressure to V-2901 may result in an inability to remove liquid from V-2901 with liquid carryover to the flash gas system. Operational issue, no safety hazard.															
	NIO-56020-00-011-2901	6. Failure of control valve / control loop FCV-2901B Closed when desired to be open. or manual valves closed	1. Loss of pilot gas. Inability to start heater treater resulting in an inability to break emulsion of recycled oil. No safety hazard, an Operational issue.															
	NIO-56020-00-011-2901	7. Failure of control valve / control loop FCV-2901A Closed when desired to be open. or SDV-2901 closed	1. Loss of fuel gas to the main burner. Potential to have insufficient heat to remove emulsion from recycled oil. No safety hazard, an operational issue.															
	NIO-56020-00-011-9201	8. Failure of control valve / control loop SDV-9201 Closed when desired to be open. [Safety System Valve]	1. Downstream pressure > 15 psig. Higher pilot gas than desired. Potential waste of fuel gas.															
			2. Downstream pressure > 15 psig. Higher pilot gas than desired potential to lift flame off of the pilot resulting in uncombusted gas from the flare stack. Environmental incident	39. BMS Flame detection will ESD well.				1	1	1	3	I	No					
	NIO-56020-00-011-9401	9. Plugging of Flame Arrestor FA-9201.	1. Blocked flow to the hp flare. Upstream pressure > 100 psig. Potential to have an environmental release of uncombusted material from the flare KO drum. A class piping @ 285 psig V-2001/2/3/4 @ 260 psig (limited by PSV-2001) Overpressure = not anticipated	45. PSV-9001 @ 125 psig vents to the atmosphere				1	1	1	2	I	No					
				46. PAHH-2001 will close ESDV on well														
3. Reverse / Mis-Directed Flow	NIO-56020-00-011-3101	1. Failure of 1" check valve to prevent back flow - line 9804 (inst gas to VRU Skid 1/2)	1. No safety hazard with failure of this check valve.															
	NIO-56020-00-011-3102																	
	NIO-56020-00-011-2901	2. Failure of 1" check valve on V-2902 overhead line.	1. No safety hazard with failure of this check valve.															
	NIO-56020-00-011-2901	3. Tube Leak in V-2901.	1. Potential for fire tube failure with oil to fuel gas resulting in ignition and fire of the treater.	36. No safeguards listed				3	2	3	3	II	No					

Heat source is incapable of causing excess temperature.	A.5.e.2
TSH Not Installed - Atmospheric Vessel	ATTENTION!
TSH installed which completely isolates fuel source from both burner and pilot and is separate from the temperature controller.	A.6.a.1
Component is a steam generator protected by a PSH and if fired protected by a LSL.	A.6.a.2
Component is an indirect water bath heater in atmospheric service and is protected by an LSL.	A.6.a.3
TSH not installed - Fired and Exhaust Heated Components - Fluid	ATTENTION!
TSH installed - Fired and Exhaust Heated Components	A.6.b.1
Cost of unit and impact to production within acceptable consequence levels	A.6.b.2
Component is isolated and does not handle combustible medium or process fluids other than fuel - Fired and Exhaust Heated Components - TSH	A.6.b.3
Component is exhaust heated without supplemental firing and medium is not combustible - Fired and Exhaust Heated Components - TSH	A.6.b.4
TSH not installed - Fired and Exhaust Heated Components - Stack	ATTENTION!
PSL installed - Fired and Exhaust Heated Components - Air - PSL	A.6.c.1
Component is equipped with a natural draft burner - Air - PSL	A.6.c.2
Forced draft burner is equipped with another type of low air supply sensor.	A.6.c.3
Component is exhaust heated without supplemental firing - Air - PSL	A.6.c.4
PSL Not Installed - Fired and Exhaust Heated Components - Air - PSL	ATTENTION!
PSH installed - Fired and Exhaust Heated Components - Fuel - PSH	A.6.e.1
Component is exhaust heated without supplemental firing - Fuel - PSH	A.6.e.2
Fuel line contains two (2) pressure controlling devices upstream of fuel flow control valve (temperature control valve)	A.6.e.3
PSH Not Installed - Fired and Exhaust Heated Components - Fuel - PSH	ATTENTION!
PSL installed - Fired and Exhaust Heated Components - Fuel - PSL	A.6.f.1
Component is equipped with a natural draft burner - Fuel - PSL	A.6.f.2
Component is exhaust heated without supplemental firing - Fuel - PSL	A.6.f.3
PSL Not Installed - Fired and Exhaust Heated Components - Fuel - PSL	ATTENTION!
BSL installed - Fired and Exhaust Heated Components	A.6.g.1
Component is exhaust heated without supplemental firing - Fired and Exhaust Heated Components - BSL	A.6.g.2
BSL not installed - Fired and Exhaust Heated Components	ATTENTION!
PSL installed - Fired and Exhaust Heated Components	A.6.h.1
Component is not a closed heat transfer type in which a combustible medium flows through tubes located in the firing or exhaust heated chamber.	A.6.h.2
PSL not installed - Fired and Exhaust Heated Components	ATTENTION!
Motor interlock installed - Fired and Exhaust Heated Components	A.6.i.1
Component is equipped with a natural draft burner - Fired and Exhaust Heated Components - MI	A.6.i.2
Component is exhaust heated without supplemental firing - Fired and Exhaust Heated Components - MI	A.6.i.3
Motor interlock not installed - Fired and Exhaust Heated Components	ATTENTION!
Flame arrestor installed - Fired and Exhaust Heated Components	A.6.l.1
Component is equipped with a forced draft burner - Fired and Exhaust Heated Components - FA	A.6.l.2
Component is located in an isolated area and not handling combustible medium or process fluids other than fuel.	A.6.l.3
Component is exhaust heated without supplemental firing - Fired and Exhaust Heated Components - FA	A.6.l.4
Flame arrestor not installed - Fired and Exhaust Heated Components	ATTENTION!
Stack arrestor installed	A.6.k.1
Bird/Bat Cone installed	A.6.k.2
Component is equipped with a forced draft burner and (i) the fluid being heated is non-flammable, or (ii) the burner draft pressure at the exit of the transfer section is higher than the fluid pressure (head).	A.6.k.3
Component is isolated so process fluids will not contact stack emissions.	A.6.k.4
Component is exhaust heated without supplemental firing.	A.6.k.5
Stack arrestor not installed	ATTENTION!
PSV installed - Fired and Exhaust Heated Components	A.6.l.1
Component is not a tube type heater.	A.6.l.2
PSV installed on another component will provide necessary protection and the PSV cannot be isolated from the tube section.	A.6.l.3
PSV Not Installed - Fired and Exhaust Heated Components	ATTENTION!
PSV installed on each outlet - Fired and Exhaust Heated Components	A.6.m.1
The maximum volume of combustible media that could backflow from downstream equipment is insignificant, or medium is not combustible.	A.6.m.2
Component is not a tube type heater.	A.6.m.3
PSV Not Installed - Fired and Exhaust Heated Components	ATTENTION!
PSH installed - Pipeline Pumps	A.7.a.1
PSH Not Installed - Pipeline Pumps	ATTENTION!
PSH installed - Other Pumps	A.7.b.1
Maximum pump discharge pressure does not exceed 70 percent of the Maximum allowable working pressure of the discharge piping.	A.7.b.2
Pump is manually operated and continuously attended - PSH	A.7.b.3
Small, low volume pumps, e.g. chemical injection pumps - PSH	A.7.b.4
Pump discharges to an atmospheric vessel - PSH	A.7.b.5
Pump is a glycol covered glycol pump.	A.7.b.6
PSH Not Installed - Other Pumps	ATTENTION!
PSL installed - Pipeline Pumps	A.7.c.1
Pump does not handle hydrocarbons.	A.7.c.2
PSL Not Installed - Pipeline Pumps	ATTENTION!
PSL installed - Other Pumps	A.7.d.1
Pump is manually operated and continuously attended - PSL	A.7.d.2
Adequate containment is provided.	A.7.d.3
Small, low volume pumps, e.g. chemical injection pumps - PSL	A.7.d.4
Pump discharges to an atmospheric vessel - PSL	A.7.d.5
PSL Not Installed - Other Pumps	ATTENTION!
PSV installed - Pipeline Pumps	A.7.e.1
Pump is a kinetic energy type and incapable of generating a head greater than the maximum allowable working pressure of the discharge piping.	A.7.e.2
PSV Not Installed - Pipeline Pumps	ATTENTION!
PSV installed - Other Pumps	A.7.f.1
Maximum pump discharge pressure is less than the maximum allowable working pressure of the discharge piping.	A.7.f.2
Pump has internal pressure relief capability.	A.7.f.3
Pump is a glycol covered glycol pump, and the wet glycol low pressure discharge piping is rated higher than the maximum discharge pressure.	A.7.f.4
Pump is a glycol covered glycol pump, and the wet glycol low pressure discharge piping is protected by a PSV on a downstream component that cannot be isolated from the pump.	A.7.f.5
PSV Not Installed - Other Pumps	ATTENTION!
Check valves installed - All Pumps	A.7.g.1
FSV Not Installed - All Pumps	ATTENTION!
PSH installed (Suction)	A.8.a.1
Each input source is protected by a PSH that will also protect the compressor.	A.8.a.2
PSH Not Installed (Suction)	ATTENTION!
PSH installed (Discharge)	A.8.b.1
Compressor is protected by a downstream PSH, located upstream of any cooler, that cannot be isolated from the compressor.	A.8.b.2
PSH Not Installed (Discharge)	ATTENTION!
PSL installed (Suction)	A.8.c.1
Each input source is protected by a PSL that will also protect the compressor.	A.8.c.2
PSL Not Installed (Suction)	ATTENTION!
PSL installed (Discharge)	A.8.d.1
Compressor is protected by a downstream PSL, located upstream of any cooler, that cannot be isolated from the compressor.	A.8.d.2
PSL Not Installed (Discharge)	ATTENTION!
PSV installed (Suction)	A.8.e.1
Each input source is protected by a PSV that will also protect the compressor.	A.8.e.2
PSV Not Installed (Suction)	ATTENTION!
PSV installed (Discharge)	A.8.f.1
Compressor is protected by a downstream PSV, located upstream of any cooler, that cannot be isolated from the compressor.	A.8.f.2
Compressor is kinetic energy type and incapable of generating a pressure greater than the maximum allowable working pressure of the compressor or discharge piping.	A.8.f.3
PSV Not Installed (Discharge)	ATTENTION!
PSV installed (Final Discharge)	A.8.g.1
PSV Not Installed (Final Discharge)	ATTENTION!
TSH installed - Compressor	A.8.h.1
TSH not installed - Compressor	ATTENTION!
PSH installed - Pipelines	A.9.a.1
Delivering pipeline protected by PSH located on upstream component.	A.9.a.2
Each input source is protected by a PSH that also protects a departing or bi-directional pipeline.	A.9.a.3
The pipeline is protected by a PSH located on a parallel component.	A.9.a.4
PSH Not Installed - Pipelines	ATTENTION!
PSL installed - Pipelines	A.9.b.1
Delivering pipeline protected by PSL located on upstream component.	A.9.b.2
Each input source is protected by a PSL that also protects a departing or bi-directional pipeline.	A.9.b.3
The pipeline is protected by a PSL located on a parallel component.	A.9.b.4

PSL Not Installed - Pipelines	ATTENTION!
<p>PSV installed - Pipelines Pipeline has a maximum allowable operating pressure greater than the maximum pressure of any input source. Each input source having a pressure greater than the maximum allowable operating pressure of the pipeline is protected by a PSV set no higher than the maximum allowable operating pressure of the pipeline. The pipeline does not receive input from the platform process. Input source is a well having a pressure greater than the maximum allowable operating pressure of the pipeline and is equipped with two SDVs (one of which may be the SSV) controlled by independent PSH. Independent PSHs connected to separate relays</p>	A.9.c.1 A.9.c.2 A.9.c.3 A.9.c.4 A.9.c.5 ATTENTION!
<p>PSV Not Installed - Pipelines FSV installed - Pipelines Departing pipeline is equipped with an SDV controlled by a PSL. Each input source is protected by an FSV located so that no significant length of pipeline is unprotected from backflow. Pipeline is used for bi-directional flow.</p>	A.9.d.1 A.9.d.2 A.9.d.3 A.9.d.4 ATTENTION!
<p>FSV Not Installed - Pipelines PSH installed - Heat Exchangers Input source to heat exchanger section cannot develop pressure greater than the maximum allowable working pressure of the heat exchanger section. Each input source is protected by a PSH that also protects the heat exchanger section. A PSH is installed on a downstream component and cannot be isolated from the heat exchanger section by block or regulating valves.</p>	A.10.a.1 A.10.a.2 A.10.a.3 A.10.a.4 ATTENTION!
<p>PSL Not Installed - Heat Exchangers PSL installed - Heat Exchangers Minimum operating pressure is atmospheric pressure when in service. PSL installed on another component will provide necessary protection and the PSL cannot be isolated from the heat exchanger section when the heat exchanger is in service.</p>	A.10.b.1 A.10.b.2 A.10.b.3 ATTENTION!
<p>PSL Not Installed - Heat Exchangers FSV installed - Heat Exchangers Each input source is protected by a PSV set no higher than the maximum allowable working pressure of the heat exchanger section and a PSV is installed on the heat exchanger section for fire exposure and thermal relief. Each input source is protected by a PSV set no higher than the maximum allowable working pressure of the heat exchanger section and that cannot be isolated from the heat exchanger section. PSVs on downstream equipment can satisfy relief requirement of the heat exchanger section and cannot be isolated from the heat exchanger section. Sources to the exchanger section can't develop pressure greater than the mawp of the exchanger section and the heat exchanger section cannot be over pressured due to temperature or pressure in the other section. Each input source is protected by a PSV set no higher than the maximum allowable working pressure on the heat exchanger section and the heat exchanger section cannot be over pressured due to temperature or pressure in the other section.</p>	A.10.c.1 A.10.c.2 A.10.c.3 A.10.c.4 A.10.c.5 A.10.c.6 ATTENTION!
<p>PSV Not Installed - Heat Exchangers Location is remote, unoccupied well site with consequence severity of 1 or 2 - SSSDS Location is a simple process or test facility with consequence severity of 1 or 2 - SSSDS Onsite controller such as a PLC or PC to shutdown compressor or treating process during upset conditions. Shut down notification alarm sent through SCADA system Complex facility with severity consequence of 3,4, or 5. Safety shutdown system is installed with appropriate consideration given to safety system components (isolation valves, fire detection, gas detections, critical alarm shutdowns) Facility is a regulated or complex facility and ESD system is required Facility is a regulated or complex facility and ESD system is required and must be segregated from the process controls</p>	A.11.a.1 A.11.a.2 A.11.a.3 A.11.a.4 A.11.a.5 A.11.a.6 ATTENTION!
<p>Location is remote, unoccupied well site with consequence severity of 1 or 2 - MSDS Location is a simple process or test facility with consequence severity of 1 or 2 - MSDS Single unit compressor station or treating process with shutdown on unit control panel Multiple unit installation or treating facility. Combined horsepower >1000 hp. Consequence severity rating is 3 >. Local PLC type controller to shut down each compressor or process during upset conditions. Shut alarm sent via SCADA. Multiple compressor installation or complex facility with severity consequence of 4 or 5. Safety system is installed with manual shutdown stations at exit points. ESD system with manual shutdown stations at exit points and at common control stations.</p>	A.11.b.1 A.11.b.2 A.11.b.3 A.11.b.4 A.11.b.5 A.11.b.6 ATTENTION!
<p>Location is a remote, normally unoccupied well site with consequence severity of 1 or 2 - Isolation Manual isolation valves installed. Location is a simple process or test facility with consequence severity of 1 or 2. Non-complex facility with manual isolation valves installed, which can still be accessed in the event of an incident at the facility. Compressor station with less than 1000 hp and manual isolation valves installed at inlet and discharge of facility, which can still be accessed in the event of an incident at the facility Actuated isolation valves installed at inlet and discharge of facility which can be initiated by personnel or safety system/ESD system components.</p>	A.11.c.1 A.11.c.2 A.11.c.3 A.11.c.4 A.11.c.5 ATTENTION!
<p>Location is remote, unoccupied well site with consequence severity of 1 or 2 with no buildings or enclosures Location is a simple process or test facility with consequence severity of 1 or 2 with no buildings or enclosures Location has no buildings or enclosures and the consequence severity of an event is not a 4 or 5 Temperature detection is installed (such as fusible plug) Flame detection is installed Smoke detection is installed Combination of 2 or more temperature/flame/some detection installed</p>	A.11.d.1 A.11.d.2 A.11.d.3 A.11.d.4 A.11.d.5 A.11.d.6 A.11.d.7 ATTENTION!
<p>Location is remote, unoccupied well site with consequence severity of 1 or 2 with no buildings or enclosures - CGDS Location is a simple process or test facility with consequence severity of 1 or 2 with no buildings or enclosures - CGDS Equipment is installed in a well ventilated location, not in a building or enclosure Equipment is installed in a building or enclosure, but processes or handles non-flammable fluids and any prime movers are not natural gas-fired Gas detection installed where equipment may be installed in inadequately ventilated buildings or enclosures. (Gas detectors should be located in area where combustible gas can accumulate)</p>	A.11.e.1 A.11.e.2 A.11.e.3 A.11.e.4 A.11.e.5 ATTENTION!
<p>Location is remote, unoccupied well site with consequence severity of 1 or 2 with no buildings or enclosures - TGDS Location is a simple process or test facility with consequence severity of 1 or 2 with no buildings or enclosures - TGDS Equipment is installed in a well ventilated location, i.e. not in a building or enclosure. Personnel wear gas detectors and off-site impact is not expected. 100 ppm ROE does not encompass public area (house, road) Gas detection installed where equipment may be installed in inadequately ventilated buildings or enclosures. (Gas detectors should be located in areas where toxic gas can accumulate) Gas detection installed at perimeter of location, due to possible public or off-site impact</p>	A.11.f.1 A.11.f.2 A.11.f.3 A.11.f.4 A.11.f.5 ATTENTION!
<p>Location is remote, unoccupied well site with consequence severity of 1 or 2 Location is a simple process or test facility with consequence severity of 1 or 2 Controls are designed to fail in a safe position if power, instrument air/gas supply is interrupted.</p>	A.11.g.1 A.11.g.2 A.11.g.3 ATTENTION!
<p>All equipment installed outdoors. Any enclosures are small and rated for the appropriate area classification Natural draft has been determined to be adequate to maintain ventilation Gas detection is installed. Enclosure/building is artificially maintained to be Cl. 1 Div. 2. Ventilation equipment has alarms in event of failure. Equipment is shut down upon gas detection. Ventilation is artificially maintained. All electrical equipment is Cl. 1, Div. 1, and there is not fired or internal combustion equipment. Ventilation is artificially maintained and ventilation equipment has malfunction alarms. All electrical equipment is Cl. 1, Div. 1. Fired or internal combustion equipment allowed.</p>	A.12.1 A.12.2 A.12.3 A.12.4 A.12.5 ATTENTION!
<p>Containment installed equal to 1.1 x largest tank capacity plus 100 year rainfall Facility is not a SPOC facility and tank capacity is > (5 times avg daily production x number of days between operator visits). LSH alarms operator through SCADA system Facility is not a SPOC facility and tank capacity is > (5 times avg daily production x number of days between operator visits). LSH shuts down operation preventing ongoing overflow situation. Containment alarm with shutdown (LSH) installed if daily tank throughput is > tank capacity.</p>	A.13.1 A.13.2 A.13.3 A.13.4 ATTENTION!

Safety Analysis Function Evaluation Chart (SAFE)

Facility Name:	Nio Bulk Facility Standard (Design)
Location:	Watkins, CO
Date Assessed:	13-Jun-19
Assessment Team:	Daniel Paul; Shaun Gravois; John Kobert
Facility Description	Nio Bulk Facility

- | | | |
|-------------------------------------|---------------------------------------|---------------------|
| PSH Pressure Sensor High | BSL Flame Failure Indicator | US Utility Systems |
| PSL Pressure Sensor Low | MI Motor Interlock | SDV Shut Down Valve |
| PSV Pressure Safety Valve | FA Flame Arrestor | |
| FSV Flow Safety Valve (Check Valve) | FD Fire Detection | |
| LSH Level Sensor High | SDDS Safety Shut Down System | |
| LSL Level Sensor Low | MDSD Manual Shut Down System | |
| TSH Temp Sensor High | CGDS Combustible Gas Detection System | |
| TSL Temp. Sensor Low | TGDS Toxic Gas Detection System | |

Function Performed
Shutdown or Control Device I.D.

Component Identification No.	Service	Equipment type	Device Type	Alternate Protection		SAC Text	Unique Device TAG / ID	Comments	Recommendations
				SAC Ref. Number	Alternate Device If Applicable				
		Buildings Enclosures	Enclosures	A.12.1		All equipment installed outdoors. Any enclosures are small and rated for the appropriate area classification			
3"-HC-S6050-00X-D1AL		Flow line Segment	PSH	A.1.a.1		PSH installed and block valves between source and PSH are locked or car sealed open - Flow Line Segment	PIT XXXX		
			PSL	A.1.b.1		PSL Installed on Flow line segment	PIT XXXX		
			PSV	A.1.c.2		Flow line segment has a maximum allowable working pressure greater than the maximum shut in pressure.			
			FSV	A.1.d.3		Can document in comments that backflow is not possible or cannot create a consequence of concern - Flow Line		Backflow is not a consequence of concern at the well head	
Artificial Lift		Flow line Segment	PSH	A.1.a.1		PSH installed and block valves between source and PSH are locked or car sealed open - Flow Line Segment			
2"-HG-S6050-19X-D1AL-1.5"H			PSL	A.1.b.1		PSL Installed on Flow line segment			
			PSV	A.1.c.2		Flow line segment has a maximum allowable working pressure greater than the maximum shut in pressure.			
			FSV	A.1.d.1		FSV installed on Flow line segment			
Bulk 3-Phase Separator SE-200		Pressure Vessels	PSH	A.4.a.1		PSH installed on Vessel	PIT XXXX		
			PSL	A.4.b.1		PSL Installed on Vessel	PIT XXXX		
			PSV	A.4.c.1		PSV installed on Vessel	PSV XXXX		
			LSH	A.4.d.1		LSH installed on Vessel	LSHH XXXX		
			LSL	A.4.e.1		LSL installed to protect each liquid outlet on Vessel	LSLL XXXX		
			FSV	A.4.f.1		FSV installed on each outlet of Vessel		Gas outlet will have insignificant hydrocarbon backflow; liquid outlet is equipped with an FSV to prevent backflow	
			TSH	A.4.g.2		Heat source is incapable of causing excess temperature.		Temperature indicator present to monitor temperature	
Test 3-Phase Separator SE-300		Pressure Vessels	PSH	A.4.a.1		PSH installed on Vessel	PIT XXXX		
			PSL	A.4.b.1		PSL Installed on Vessel	PIT XXXX		
			PSV	A.4.c.1		PSV installed on Vessel	PSV XXXX		
			LSH	A.4.d.1		LSH installed on Vessel	LSHH XXXX		
			LSL	A.4.e.1		LSL installed to protect each liquid outlet on Vessel	LSLL XXXX		
			FSV	A.4.f.1		FSV installed on each outlet of Vessel		Gas outlet will have insignificant hydrocarbon backflow; liquid outlet is equipped with an FSV to prevent backflow	
			TSH	A.4.g.2		Heat source is incapable of causing excess temperature.		Temperature indicator present to monitor temperature	
Bulk Heater Treater HT-400		Pressure Vessels	PSH	A.4.a.1		PSH installed on Vessel	PIT XXXX		
			PSL	A.4.b.1		PSL Installed on Vessel	PIT XXXX		
			PSV	A.4.c.1		PSV installed on Vessel	PSV XXXX		
			LSH	A.4.d.1		LSH installed on Vessel	LSHH XXXX		
			LSL	A.4.e.1		LSL installed to protect each liquid outlet on Vessel	LSLL XXXX		
			FSV	A.4.f.1		FSV installed on each outlet of Vessel			

Phase 2 Safe Chart
Safety Analysis Function Evaluation Chart (SAFE)

Facility Name:	Nio Bulk Facility Standard (Design)
Location:	Watkins, CO
Date Assessed:	13-Jun-19
Assessment Team:	Daniel Paul; Shaun Gravois; John Kobert
Facility Description	Nio Bulk Facility

- | | | |
|-------------------------------------|---------------------------------------|---------------------|
| PSH Pressure Sensor High | BSL Flame Failure Indicator | US Utility Systems |
| PSL Pressure Sensor Low | MI Motor Interlock | SDV Shut Down Valve |
| PSV Pressure Safety Valve | FA Flame Arrestor | |
| FSV Flow Safety Valve (Check Valve) | FD Fire Detection | |
| LSH Level Sensor High | SSDS Safety Shut Down System | |
| LSL Level Sensor Low | MDSO Manual Shut Down System | |
| TSH Temp Sensor High | CGDS Combustible Gas Detection System | |
| TSL Temp. Sensor Low | TGDS Toxic Gas Detection System | |

Component Identification No.	Service	Equipment type	Device Type	Alternate Protection		SAC Text	Unique Device TAG / ID	Comments	Recommendations
				SAC Ref. Number	Alternate Device If Applicable				
			TSH	A.4.g.1		TSH installed on Vessel	TSHH XXXX		
Bulk HT Burner	Fired or Exhaust Heated Equipment		TSH_Fluid	A.6.a.1		TSH installed which completely isolates fuel source from both burner and pilot and is separate from the temperature controller.	TSH XXXX		
HT-400			TSH_Stack	A.6.b.2		Cost of unit and impact to production within acceptable consequence levels			
			PSL_Air	A.6.d.2		Component is equipped with a natural draft burner - Air - PSL			
			PSH	A.6.e.3		Fuel line contains two (2) pressure controlling devices upstream of fuel flow control valve (temperature control valve)	PCV XXXX (fuel gas) PCV XXXX (burner)		
			PSL_Fuel	A.6.f.2		Component is equipped with a natural draft burner - Fuel - PSL			
			BSL	A.6.g.1		BSL installed - Fired and Exhaust Heated Components	BSL XXXX		
			FSL	A.6.h.2		Component is not a closed heat transfer type in which a combustible medium flows through tubes located in the firing or exhaust heated chamber.			
			MI	A.6.i.2		Component is equipped with a natural draft burner - Fired and Exhaust Heated Components - MI			
			FA_Intake	A.6.j.1		Flame arrestor installed - Fired and Exhaust Heated Components	FA XXXX		
			SA	A.6.k.2		Bird/Bat Cone installed			
			PSV	A.6.l.2		Component is not a tube type heater.			
			FSV	A.6.l.2		Component is not a tube type heater.			
Test Heater Treater	Pressure Vessels		PSH	A.4.a.1		PSH installed on Vessel	PIT XXXX		
HT-410			PSL	A.4.b.1		PSL Installed on Vessel	PIT XXXX		
			PSV	A.4.c.1		PSV installed on Vessel	PSV XXXX		
			LSH	A.4.d.1		LSH installed on Vessel	LSHH XXXX		
			LSL	A.4.e.1		LSL installed to protect each liquid outlet on Vessel	LSLL XXXX		
			FSV	A.4.f.1		FSV installed on each outlet of Vessel			
			TSH	A.4.g.1		TSH installed on Vessel	TSHH XXXX		
Test HT Burner	Fired or Exhaust Heated Equipment		TSH_Fluid	A.6.a.1		TSH installed which completely isolates fuel source from both burner and pilot and is separate from the temperature controller.	TSH XXXX		
HT-410			TSH_Stack	A.6.b.2		Cost of unit and impact to production within acceptable consequence levels			
			PSL_Air	A.6.d.2		Component is equipped with a natural draft burner - Air - PSL			
			PSH	A.6.e.3		Fuel line contains two (2) pressure controlling devices upstream of fuel flow control valve (temperature control valve)	PCV XXXX (fuel gas) PCV XXXX (burner)		
			PSL_Fuel	A.6.f.2		Component is equipped with a natural draft burner - Fuel - PSL			
			BSL	A.6.g.1		BSL installed - Fired and Exhaust Heated Components	BSL XXXX		
			FSL	A.6.h.2		Component is not a closed heat transfer type in which a combustible medium flows through tubes located in the firing or exhaust heated chamber.			
			MI	A.6.i.2		Component is equipped with a natural draft burner - Fired and Exhaust Heated Components - MI			
			FA_Intake	A.6.j.1		Flame arrestor installed - Fired and Exhaust Heated Components	FA XXXX		
			SA	A.6.k.2		Bird/Bat Cone installed			
			PSV	A.6.l.2		Component is not a tube type heater.			
			FSV	A.6.l.2		Component is not a tube type heater.			
Tank Vapor / VRT VRU	Compressors		PSH_Suction	A.8.a.1		PSH installed (Suction)	PIT XXXX (Vendor Package)		
VRU-710			PSH_Discharge	A.8.b.1		PSH installed (Discharge)	PIT XXXX (Vendor Package)		
VRU-711			PSL_Suction	A.8.c.2		Each input source is protected by a PSL that will also protect the compressor.		VRU inlet is from atmospheric vessel, designed to operate at low suction pressures	

Function Performed
Shutdown or Control Device I.D.

Nodes

Nodes	Design Intent	Failures	Drawings	Session	Comment
1. Well Head, HP / LP Separator (Heater Treater) Green - Os Sales Gas Orange - Xs	Well Head - 500 psig may be > 1000 psig Design Pressure: 5000 psig including choke Pipeline - D1 Class Piping Design Pressure: 1440 psig A Class Piping: 285 psig V-2001/2/3/4 HP Separator DP/T = 260 psig / 200 F PSV-2001 @ 280 psig vents to atms V-2101/2/3/4/5 LP Separator DP/T = 125 psig / 350 F PSV-2102 @ 125 psig vents to atms	1. ESDV-100x Choke 100x PCV-2002/3/4A PCV-2011A	NIO-S6020-00-011- 1001 NIO-S6020-00-011- 2001 NIO-S6020-00-011- 2002 NIO-S6020-00-011- 2003 NIO-S6020-00-011- 2004 NIO-S6020-00-011- 3001 NIO-S6020-00-011- 7000 NIO-S6020-00-011- 7101		
2. Flash Gas / VRU Purple - - - - (dashed line)	V-3101/3102 Suction Scrubber DP/T = 100 psig / ??? F PSV-3100 @ 100 psig vents to atms EA-3122 DP = 250 psig	1. PCV- 2001/2/3/4B PCV- 2101/2/3/4C PCV-2901D PCV-3110	NIO-S6020-00-011- 2001 NIO-S6020-00-011- 2002 NIO-S6020-00-011- 2003 NIO-S6020-00-011- 2004 NIO-S6020-00-011- 2901 NIO-S6020-00-011- 3001 NIO-S6020-00-011- 3100 NIO-S6020-00-011- 3101 NIO-S6020-00-011- 3102 NIO-S6020-00-011- 7000		
3. Flash Gas / Vent Orange - ^^^^^	V-9301/02 DP/T = 125 psig / ?? T PSV-9301/02 @ 125 psig B-9401 Combuster DP/T = ??? Refractory Lined CS Vessel	1. FA-9401/02 FA-9410 PCV-3100 PCV-4101 SDV-9400A/B	NIO-S6020-00-011- 3100 NIO-S6020-00-011- 4001 NIO-S6020-00-011- 4002 NIO-S6020-00-011- 4101 NIO-S6020-00-011- 9301 NIO-S6020-00-011- 9401		
4. Oil to VRT Pink Diamonds	V-2901 Recycle Heater DP/T = 125 psig / 350 F PSV-2901 @ 125 psig vents to atms V-3001 DP/T = 125 psig / 200 F PSV-3001 @ 125 psig vents to atms	1. LCV- 2101/2/3/4A LCV-2901A	NIO-S6020-00-011- 2001 NIO-S6020-00-011- 2002 NIO-S6020-00-011- 2003 NIO-S6020-00-011- 2004		

Nodes	Design Intent	Failures	Drawings	Session	Comment
	P-4201 Recycle Pump 2 hp Delta P = 100 psig		NIO-S6020-00-011-2901 NIO-S6020-00-011-3001 NIO-S6020-00-011-4000 NIO-S6020-00-011-4001 NIO-S6020-00-011-4002 NIO-S6020-00-011-4101		
5. Produced Water Blue Squares	P-3111/12 Condensate Removal Pump 1 HP - Disch Press ~ 100 psig P-9001 KO Drum Pump 2 HP P-9301/02 10 GPM Dead Head Pressure = ???? TK-4101/2 Atmos Storage Tanks PVRV-4101/2 @ 16 oz vent to atms	1. LCV-2901/2/3/4B LCV-2901B	NIO-S6020-00-011-2001 NIO-S6020-00-011-2002 NIO-S6020-00-011-2003 NIO-S6020-00-011-2004 NIO-S6020-00-011-2901 NIO-S6020-00-011-3101 NIO-S6020-00-011-3102 NIO-S6020-00-011-4100 NIO-S6020-00-011-4101 NIO-S6020-00-011-9001 NIO-S6020-00-011-9301		
6. Fuel Gas Green / / / / Flare Yellow Line	V-2201/2/3/4 Fuel Gas Scrubber DP/T = 125 psig / 200 F PSV-2201 @ 125 psig vents to atms V-2902 DP/T = 125 psig / 200 F PSV-2902 @ 125 psig vent to atms V-9001 DP/T = 125 psig / ?? F PSV-9001 @ 125 vents to atms	1. FA-9201 FCV-2101/2/3/4A FCV-2901A/B PCV-2201 PCV-2101/2/3/4A PCV-2101/2/3/4 PCV-2901A/B PCV-7100 PCV-9400 SDV-2101 SDV-2901 SDV-9420	NIO-S6020-00-011-2001 NIO-S6020-00-011-2002 NIO-S6020-00-011-2003 NIO-S6020-00-011-2004 NIO-S6020-00-011-2101 NIO-S6020-00-011-2102 NIO-S6020-00-011-2103 NIO-S6020-00-011-2104 NIO-S6020-00-011-2901 NIO-S6020-00-011-7000 NIO-S6020-00-011-9001 NIO-S6020-00-011-9201 NIO-S6020-00-011-9401		

Niobrara Quad Well Design Risk Assessment
Cyndee R. Clouse, Certified Facilitator / Michael H. Mead, Engineer of Record
January 29, 2018

Nodes	Design Intent	Failures	Drawings	Session	Comment
			NIO-S6020-00-011-9800		

Phase 2 Safe Chart
Safety Analysis Function Evaluation Chart (SAFE)

Facility Name:	Nio Bulk Facility Standard (Design)
Location:	Watkins, CO
Date Assessed:	13-Jun-19
Assessment Team:	Daniel Paul; Shaun Gravois; John Kobert
Facility Description	Nio Bulk Facility

- | | | |
|-------------------------------------|---------------------------------------|---------------------|
| PSH Pressure Sensor High | BSL Flame Failure Indicator | US Utility Systems |
| PSL Pressure Sensor Low | MI Motor Interlock | SDV Shut Down Valve |
| PSV Pressure Safety Valve | FA Flame Arrestor | |
| FSV Flow Safety Valve (Check Valve) | FD Fire Detection | |
| LSH Level Sensor High | SSDS Safety Shut Down System | |
| LSL Level Sensor Low | MDS Manual Shut Down System | |
| TSH Temp Sensor High | CGDS Combustible Gas Detection System | |
| TSL Temp. Sensor Low | TGDS Toxic Gas Detection System | |

Component Identification No.	Service	Equipment type	Device Type	Alternate Protection		SAC Text	Unique Device TAG / ID	Comments	Recommendations
				SAC Ref. Number	Alternate Device If Applicable				
Water Storage Tanks T-2000/T-2010		Atmospheric Vessels	Vent	A.5.a.1		Vent installed - Atmospheric Vessel	LP Vent Line		
			PSV	A.5.b.2		Vessel has second vent capable of handling maximum gas volume	Thief Hatch		
			LSH	A.5.c.1		LSH installed - Atmospheric Vessel	LSH XXXX / LSH XXXX		
			LSL	A.5.d.4		Component is final vessel in a containment system designed to collect and direct hydrocarbon liquids to a safe location.			
			TSH	A.5.e.1		High temperature sensors are applicable only to vessels having a heat source.			
Tank Containment		Tank Containment Systems and Sumps	Containment	A.13.1		Containment installed equal to 1.1 x largest tank capacity plus 100 year rainfall			
Recycle Pump PD-430		Pumps	PSH Pipeline Pumps		N/A				
			PSH Other Pumps	A.7.b.3		Pump is manually operated and continuously attended - PSH			
			PSL Pipeline Pumps		N/A				
			PSL Other Pumps	A.7.d.2		Pump is manually operated and continuously attended - PSL			
			PSV Pipeline Pumps		N/A				
			PSV Other Pumps	A.7.f.2		Maximum pump discharge pressure is less than the maximum allowable working pressure of the discharge piping.			
			FSV	A.7.g.1		Check valve installed - All Pumps			
LACT Pump LACT-1000 / P-1502		Pumps	PSH Pipeline Pumps		N/A				
			PSH Other Pumps	A.7.b.2		Maximum pump discharge pressure does not exceed 70 percent of the Maximum allowable working pressure of the discharge piping.			
			PSL Pipeline Pumps		N/A				
			PSL Other Pumps	A.7.d.2		Pump is manually operated and continuously attended - PSL	PIT XXX (Vendor Drawings)		
			PSV Pipeline Pumps		N/A				
			PSV Other Pumps	A.7.f.3		Pump has internal pressure relief capacity.	PSV XXX (Vendor Drawings)		
			FSV	A.7.g.1		Check valve installed - All Pumps			

Function Performed
Shutdown or Control Device I.D.

Phase 2 Safe Chart
Safety Analysis Function Evaluation Chart (SAFE)

Facility Name:	Nio Bulk Facility Standard (Design)
Location:	Watkins, CO
Date Assessed:	13-Jun-19
Assessment Team:	Daniel Paul; Shaun Gravois; John Kobert
Facility Description	Nio Bulk Facility

- | | | |
|-------------------------------------|---------------------------------------|---------------------|
| PSH Pressure Sensor High | BSL Flame Failure Indicator | US Utility Systems |
| PSL Pressure Sensor Low | MI Motor Interlock | SDV Shut Down Valve |
| PSV Pressure Safety Valve | FA Flame Arrestor | |
| FSV Flow Safety Valve (Check Valve) | FD Fire Detection | |
| LSH Level Sensor High | SSDS Safety Shut Down System | |
| LSL Level Sensor Low | MSDS Manual Shut Down System | |
| TSH Temp Sensor High | CGDS Combustible Gas Detection System | |
| TSL Temp. Sensor Low | TGDS Toxic Gas Detection System | |

Function Performed
Shutdown or Control Device I.D.

Component Identification No.	Service	Equipment type	Device Type	Alternate Protection		SAC Text	Unique Device TAG / ID	Comments	Recommendations
				SAC Ref. Number	Alternate Device If Applicable				
LACT Sample Receiver LACT-1000 / V-1501		Pressure Vessels	PSH	A.4.a.6		Vessel operates at atmospheric pressure and has an adequate vent system.			
			PSL	A.4.b.5		Operates <250 psi and the line is monitored weekly.			
			PSV	A.4.c.1		PSV installed on Vessel			
			LSH	A.4.d.5		Vessel is a small trap from which liquids are manually drained.			
			LSL	A.4.e.2		Liquid level is not automatically maintained in the vessel and the vessel does not have an immersed heating element subject to excess temperature.			
			FSV	A.4.f.1		FSV installed on each outlet of Vessel			
			TSH	A.4.g.2		Heat source is incapable of causing excess temperature.			
LACT Sample Circulation Pump		Pumps	PSH Pipeline Pumps		N/A				
LACT-1000 / P-1503			PSH_Other_Pumps	A.7.b.2		Maximum pump discharge pressure does not exceed 70 percent of the Maximum allowable working pressure of the discharge piping.			
			PSL Pipeline Pumps		N/A				
			PSL_Other_Pumps	A.7.d.3		Adequate containment is provided.			
			PSV Pipeline Pumps		N/A				
			PSV_Other_Pumps	A.7.f.1		PSV installed - Other Pumps			
			FSV	A.7.g.1		Check valve installed - All Pumps			
LACT Sump Pump P-1504		Pumps	PSH Pipeline Pumps		N/A				
			PSH_Other_Pumps	A.7.b.5		Pump discharges to an atmospheric vessel - PSH			
			PSL Pipeline Pumps		N/A				
			PSL_Other_Pumps	A.7.d.3		Adequate containment is provided.			
			PSV Pipeline Pumps		N/A				
			PSV_Other_Pumps			PSV installed - Other Pumps			
			FSV			Check valve installed - All Pumps			
Flash Gas Combustor KO Drum PV-740		Pressure Vessels	PSH	A.4.a.5		Vessels is final scrubber in a flare, relief, or vent system and is designed to withstand maximum built up back pressure - Header			
			PSL	A.4.b.5		Operates <250 psi and the line is monitored weekly.			
			PSV	A.4.c.1		PSV installed on Vessel	PSV XXXX		
			LSH	A.4.d.1		LSH installed on Vessel	LSHH XXXX		
			LSL	A.4.e.3		Downstream equipment safely handle gas rates. Vessel doesn't have an immersed heating element. Economic consequences of gas blowby are acceptable.No environmental concerns from venting gas.		no consequence (Low level is desired)	
			FSV	A.4.f.4		Can document in comments that backflow is not possible or cannot create a consequence of concern - Pressure Vessel	Pump prevents liquid backflow; gas will have insignificant backflow		
			TSH	A.4.g.2		Heat source is incapable of causing excess temperature.			
Flash Gas Combustor KO Drum Pump PD-740		Pumps	PSH Pipeline Pumps		N/A				
			PSH_Other_Pumps	A.7.b.5		Pump discharges to an atmospheric vessel - PSH			
			PSL Pipeline Pumps		N/A				
			PSL_Other_Pumps	A.7.d.3		Adequate containment is provided.			
			PSV Pipeline Pumps		N/A				

Phase 2 Safe Chart
Safety Analysis Function Evaluation Chart (SAFE)

Facility Name:	Nio Bulk Facility Standard (Design)
Location:	Watkins, CO
Date Assessed:	13-Jun-19
Assessment Team:	Daniel Paul; Shaun Gravois; John Kobert
Facility Description	Nio Bulk Facility

- | | | |
|-------------------------------------|---------------------------------------|---------------------|
| PSH Pressure Sensor High | BSL Flame Failure Indicator | US Utility Systems |
| PSL Pressure Sensor Low | MI Motor Interlock | SDV Shut Down Valve |
| PSV Pressure Safety Valve | FA Flame Arrestor | |
| FSV Flow Safety Valve (Check Valve) | FD Fire Detection | |
| LSH Level Sensor High | SSDS Safety Shut Down System | |
| LSL Level Sensor Low | MDS Manual Shut Down System | |
| TSH Temp Sensor High | CGDS Combustible Gas Detection System | |
| TSL Temp. Sensor Low | TGDS Toxic Gas Detection System | |

Function Performed
Shutdown or Control Device I.D.

Component Identification No.	Service	Equipment type	Device Type	Alternate Protection		SAC Text	Unique Device TAG / ID	Comments	Recommendations
				SAC Ref. Number	Alternate Device If Applicable				
Chemical Pump PD-900 PD-901		Pumps	PSH Pipeline Pumps PSH Other Pumps PSL Pipeline Pumps PSL Other Pumps PSV Pipeline Pumps PSV Other Pumps FSV	A.7.b.4 A.7.d.4 A.7.f.1 A.7.g.1	N/A N/A N/A	Small, low volume pumps, e.g. chemical injection pumps - PSH Small, low volume pumps, e.g. chemical injection pumps - PSL PSV installed - Other Pumps Check valve installed - All Pumps	PSV XXXX		
Chemical Storage Tank T-900		Atmospheric Vessels	Vent PSV LSH LSL TSH	A.5.a.1 A.5.b.4 A.5.c.2 A.5.d.2 A.4.g.2		Vent installed - Atmospheric Vessel Vessel has no pressure sources (except blanket gas and/or manual drains) and is equipped with an adequately sized vent. Fill operations are continually attended. Adequate containment system is provided. Heat source is incapable of causing excess temperature.			
Environmental Tank T-5000		Atmospheric Vessels	Vent PSV LSH LSL TSH	A.5.a.1 A.5.b.4 A.5.c.4 A.5.d.2 A.4.g.2		Vent installed - Atmospheric Vessel Vessel has no pressure sources (except blanket gas and/or manual drains) and is equipped with an adequately sized vent. Tank volume is sized to contain the volume produced in 3 times the normal route check rate (i.e. tank volume > 3 times avg daily production x number of days between operator visits) Adequate containment system is provided. Heat source is incapable of causing excess temperature.			
Drain Pump PD-5000		Pumps	PSH Pipeline Pumps PSH Other Pumps PSL Pipeline Pumps PSL Other Pumps PSV Pipeline Pumps PSV Other Pumps FSV	A.7.b.5 A.7.d.5 A.7.f.2 A.7.g.1	N/A N/A	Pump discharges to an atmospheric vessel - PSH Pump discharges to an atmospheric vessel - PSL Maximum pump discharge pressure is less than the maximum allowable working pressure of the discharge piping. Check valve installed - All Pumps			