

## ***Fourth Submission Review – RESPONSES (REV 5)***

**1. Planning** (Erik Gates / 303-739-7132 / egates@auroragov.org / Comments in teal)

**1A.** There were no more comments from Planning on this review.

**2. Fire/Life Safety** (William Polk / 303-739-7371 / wpolk@auroragov.org / Comments in blue)

[Site Plan Page 4]

2A. Repeat request: All traffic gate labels must include width, operating mechanism, Knox hardware, automatic/manual, etc., details. Example: “24' Automatic Sliding Gate with approved Siren Operated System, Knox Key Switch and Manual Release.” Typical.

**ADDED LABELS TO SITE PLAN SHEET 4 AND SHEET 5**

2B. Example: “30' Automatic Sliding Gate with approved Siren Operated System, Knox Key Switch and Manual Release.” Typical.

[Site Plan Page 5]

**ADDED LABELS TO SITE PLAN SHEET 4 AND SHEET 5**

2C. Please verify the manway gates are accessible/ADA compliant.

**VERIFIED AND NOTED ADA COMPLIANT SHEET 4 AND SHEET 5**

2D. Please revise the acronym to SOS. Typical.

**REVISED ACRONYM SHEET 5**

2E. Please identify if this gate is automatic or manual.

[Site Plan Page 6]

**REVISED GATE TITLES SHEET 6**

2F. Advisory comment: The approval of this site plan amendment doesn't constitute a building permit approval or construction of the proposed elements. Gating specific information will be reviewed and approved at the time of building permit submittal.

**3. Traffic Engineering** (Carl Harline / 303-739-7584 / charline@auroragov.org / Comments in amber)

**3A.** There were no more comments from Traffic Engineering on this review.

**4. Real Property** (Maurice Brooks / 303-739-7294 / mbrooks@auroragov.org / Comments in magenta)

[Site Plan Page 4]

4A. These fences and gates need to be covered by a License Agreement. This Site Plan Amendment will not be approved until the License Agreement is completed (this is a repeated comment)

**ADDED REFERENCE NOTE TO DRAWINGS IN THE AMENDMENTS BLOCK**