



Planning Division  
15151 E. Alameda Parkway, Ste. 2300  
Aurora, Colorado 80012  
303.739.7250

*Worth Discovering • auroragov.org*

December 4, 2019

Jon Van Der Voorde, Senior Project Manager  
Newland Communities  
6312 S Fiddlers Green Cir, Suite 435N  
Greenwood Village, CO 80111

**Re: Technical Submission Review - Rockinghorse CSP No 11 Amendment – CSP w/ Waiver**  
Application Number: **DA-1370-35**  
Case Numbers: **2017-4018-01**

Dear Mr. Van Der Voorde:

Thank you for your technical submission, which we started to process on November 8, 2019. We reviewed it and have determined that the project is ready to be finalized. Please note that a request was made by Civil Engineering to label railings on retaining walls. Additionally, please thicken the clouds on the plan for legibility purposes.

Please provide a digital file of the finalized redlined plan sheets so that the official site plan file can be updated.

As always, if you have any comments or concerns, please give me a call. I may be reached at (303) 739-7184 or at [hlamboy@auroragov.org](mailto:hlamboy@auroragov.org).

Sincerely,

Heather Lamboy, Planning Supervisor  
City of Aurora Planning Department

cc: Mindy Parnes, Planning Department  
Ryan McBreen, Norris Design, 1101 Bannock St, Denver CO 80204  
Filed: k:\\$DA\1370-35tech



## *Technical Submission Review*

### **SUMMARY OF KEY COMMENTS FROM ALL DEPARTMENTS**

- ✓ Please label the railing in the wall detail.

### **PLANNING DEPARTMENT COMMENTS**

#### **1. Community Questions Comments and Concerns**

No community comments were received.

### **REFERRAL COMMENTS FROM OTHER DEPARTMENTS AND AGENCIES**

#### **3. Civil Engineering**

Kristin Tanabe, [ktanabe@auroragov.org](mailto:ktanabe@auroragov.org) 303-739-7306

##### General

1. Pedestrian railing or fencing is required on all retaining walls greater than 30", please label.