

Planning Division
15151 E. Alameda Parkway, Ste. 2300
Aurora, Colorado 80012
303.739.7250



June 12, 2019

Chad Vanengen
Magellan Midstream Partners, LP
One Williams Center OTC-9
Tulsa, Ok 74172

Re: Magellan Pipeline

Case Number: 1993-6016-13

Dear Mr. Vanengen:

Thank you for your initial submission for the above named minor amendment. Please review the attached site plan with comments to see where each comment belongs. We reviewed your plans and have the following comment:

A. Aurora Water Steven Dekoskie 303-739-7490 sdekoski@auroragov.org

1. Include all pipe size and type on the site plan.
2. There is an 8" PVC water main in the utility easement. The proposed pipe will require a license agreement. A profile showing the proposed process line crossing the water main will be required. Process piping to be installed with a casing pipe with 2' min clearance. Proposed crossing to be under the water main. Show and label water main sizes.
3. Is there a new hydrant being proposed? Is this to replace the existing? If you have to move the existing hydrant, then it will require disconnection at the main.
4. The 12" PVC water main is in the utility easement. What is the proposed height of this crossing through the utility easement? A license agreement will be required for encroachments into the U.E.

B. Real Property Grace Gray 303-739-7277 ggray@auroragov.org

1. A license agreement will be required for the pipeline and/or equipment crossing a fire lane and easement. Contact Grace Gray for license agreement information.
2. Clearly show the depth the pipe will be buried. It needs to be at least a minimum of 15 feet.

Please resubmit your work with the requested change. You may email it directly to me at wbarrett@auroragov.org . Should you have any questions you may contact me via email or by calling 303.739.7133

Sincerely,

W. David Barrett
Sr. Planner II